



شركة مصفاة البترول الاردنية المساهمة المحدودة

عمان - الأردن

مناقصة : -(116/2023) رقم طلب المواد (23010455) المواد المطلوبة توريد وحدات اناارة مقاومه للانفجار ووحدات اناارة عادية LED

الموضوع :- دعوة للاشتراك في مناقصة محلية

ترغب شركة مصفاة البترول الاردنية بشراء المواد المبينة تفصيلها ومواصفاتها الفنية في الكشف المرفق وباعتباركم مورداً لهذه المواد نوجه هذه الدعوة لكم للاشتراك بالمناقصة اعلاه وتقديم عرض سعر للمواد المطلوبة اذا وجدتم ان بإمكانكم تنفيذه مع الالتزام بكافة الشروط والمواصفات وفيما يلي الشروط العامة للمناقصة :-

1. يقدم العرض (نسختين) قبل الموعد المحدد ادناه ضمن ظرف مغلق ومختوم مبينا عليه رقم المناقصة وتاريخ الاغلاق واسم وعنوان المناقص ويسلم باليد الى (دائرة المشتريات الإدارة لعامة - جبل عمان - الدوار الأول) ولا يقبل اي عرض يرسل بالفاكس نهائيا .
2. يجب ان يكون العرض مروسا باسم وعنوان المورد موقعا ومختوما بالخاتم الرسمي للمناقص ومرفقا بصورة الشروط موقعة ومختومة منه لتأكيد التزامه بكافة الشروط والمواصفات وكذلك تقديم نسخة من السجل التجاري ورخصة المهن .
3. على المناقص تثبيت الاسعار الافرازية والاجمالية على عرضه رقما وكتابة بخط واضح دون تصحيح او كشط او محو .
4. على المناقص بيان الامور التالية في عرضه بوضوح :-
 - شمول السعر لضريبة المبيعات 16% او اية نسبة تحدد بعرض السعر والرسوم الجمركية .
 - في حال وجود اي خدمة اضافية يراد تقديمها في العرض وغير واردة في مواصفات طلب المواد او امر الشراء يجب ان يتم ذكرها بالتفصيل وان يتم بيان كلفتها المالية بشكل واضح .
 - مدة صلاحية الاسعار (يجب ان لاتقل عن (90) يوم من تاريخ تقديم العرض وخلاف ذلك يحق للمصفاة استبعاد العرض) .
 - اجور النقل الى مستودعاتنا في الزرقاء يجب ان تكون مشمولة ضمن السعر المعروض والتوريد على دفعات شهرية وحسب الطلب .
 - ان المواد المعروضة جديدة وغير مستعملة او مجددة وخالية من العيوب مع بيان سنة الصنع .
 - ان يحدد منشأ البضاعة والالتزام بتقديم شهادة بلد المنشأ وتحديد اسم الشركة الصانعة , مده التوريد , مكان التسليم علماً ان مكان التسليم المطلوب هو (الزرقاء) .
 - تثبيت السعر الافرازي والاجمالي رقما وكتابه بخط واضح دون شطب او تعديل .
5. على المناقص تقديم شهادة منشأ عند توريد المواد (مصدقة اصولا او تشير للبيان الجمركي)
6. الشركة غير ملزمة بالإحالة على اقل الاسعار ويحق لها رفض اي عرض دون ابداء الاسباب .
7. يحق للشركة الغاء المناقصة او اعادة طرحها او شراء جزء منها او التعديل على الكميات المطلوبة دون بيان الاسباب ودون ان تتحمل اي مسؤولية أياً كان نوعها .

✓

Amr

8. على المناقص عدم مراجعة اي جهة فنية في الشركة الا بالتنسيق مع دائرة المشتريات
9. المواد المطلوبة خاضعة للزيادة والنقصان بنسبة $\pm 25\%$ على ان يلتزم المناقص بتقديم عينات للبنود المطلوبه
- 10 يلتزم المناقص بقبول الإحالة الجزئية .
11. يلتزم المناقص بدفع قيمة طواع الواردات والبالغة (6) بألاف على قرار الاحالة خلال عشرة ايام من تبليغه بالقرار .
12. على المناقص تقديم كفالة حسن تنفيذ غير مشروطة بنسبة 10% من القيمة الاجمالية (بعد الاحالة) لحين استلام المواد والموافقة عليها.
14. على المناقص تقديم كفالة صيانة غير مشروطة بنسبة 5% من القيمة الاجمالية (بعد الاحالة) .
13. يتم دفع ثمن المواد المشتراه بعد استلام المواد في مستودعات الشركة وبعد صدور سند استلام يؤكد استلامها كاملة ومطابقة للشروط والمواصفات .
14. في حال تأخير توريد / تنفيذ المناقصة حسب ما تم الاتفاق عليه يترتب عليكم غرامة قدرها (20) دينار اردني عن كل يوم تأخير
15. في حال اخلال المتعهد المحال عليه المناقصة باي من التزامات , يحق للشركة الغاء الاحالة واللجوء الى طرف ثالث دون الحاجة لأي اخطار او انذار عادي او عدلي ودون الحاجة لمراجعة القضاء وتحميل المتعهد كافة التكاليف المترتبة على ذلك .
16. تعتبر هذه الشروط جزءاً لا يتجزأ من المناقصة وعلى المورد الالتزام بما جاء فيها .
17. اخر موعد لقبول واستلام العروض الساعة الثانية عشره والنصف من ظهر يوم الخميس الموافق 2023/6/8 وتسلم لدائرة المشتريات - الادارة العامة - جبل عمان - الدوار الأول . وتسليم العروض في مكتب رقم 10
18. في حال وجود أي استفسار يتم إرساله بالبريد الإلكتروني على العنوان (Purchasing@jopetrol.com.jo) .
19. يجب ان تكون الفاتورة المقدمة من قبلكم في حال شراء السلع او تقديم خدمة وفقاً لنظام تنظيم شؤون الفوترة والرقابة عليها رقم (34) لسنة 2019 وسيتم رفض أي فاتورة لا تكون وفقاً للنظام أعلاه .
- كما يشترط تقديم البيانات التالية على الفواتير الصادرة من قبلكم :-
- الاسم الكامل للشخص أو الشركة أو المفوض بالتوقيع وختم الشركة الرسمي او المفوض بالتوقيع وتوقيعه.
- الرقم الوطني الكامل للشخص أو الشركة أو المفوض بالتوقيع .
- العنوان الكامل بالإضافة إلى رقم الهاتف والصندوق البريدي والرمز البريدي .
- الرقم الضريبي للشخص أو الشركة إن وجد .
- يرجى الالتزام بالملحق



Quote Order

Order Number 23010287 OQ 00001

Delivery Instructions

Branch/Plant 2002
Order Date 15/05/2023
Request Date 11/11/2023
Freight Handling

General Description 1 161113

Weather proof LED flood lighting fixture
Voltage range : 100-260VAC, frequency : 50HZ
Cable entries : 3/4 inch cable gland, IP56
Operating temperature : -10 to +45 °C
Service life : >50000 hour, Color temperature : cool white, clear glass.
Luminous efficiency : >130 lm/W.
Power factor : >0.95, THD : <15%, Beam angle>140 Degree.
Body material: Aluminum, with Adjustable U-Shaped yoke mount
Each fixture shall be provided complete with driver, cable gland.
The warranty period for the fixtures shall be not less than five years.
Manufacturer shall provide the following documents with his offer:
1. Tests reports that explain the lux reading at different height.
2. Technical data sheet including dimensions
3. Installation and maintenance instructions.
6. Manufacturer quality control plan

General Description 2

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Price	Supplier Offer Currency	Original Order No	Type	Lin
1	1603585060	LED FLOOD LIGHTING 150W,	20000 Lumen		100.000	EA			23010455	OR	

General Description 1 161061

LED lighting panel
Dimensions : square 600X600 mm
Voltage range : 100-270VAC
Rated frequency : 50HZ
Rated power: 36W
Ingress protection : IP42
Operating temperature : -5 to +45 °C
Service life : >50000 hour.
Color temperature : 6000-6500K (cool white) .
Luminous efficiency : >90 lm/W.

Jordan Petroleum Refinery Company

Quote Order

Order Number 23010287 OQ 00001

Date 15/05/2023
Page - 2

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Unit Price	Supplier Offer Currency Code	Original Order No	Type	Lin
		Power factor : >0.95 Luminous flux>3600 Lm. THD : <15%. Beam angle>120 Degree. Warranty : 5 years for fixtures and drivers . Each fixture shall be provided complete with good quality driver, ceiling type installation. sample of the units shell be tested in local laboratory included in offer prices Manufacturer shall be provide the following documents with his offer : 1. Tests reports explain the lux reading for 3mtr and 4mtr height. 2. Technical data sheet including dimensions 3. Installation and maintenance instructions. 4. EU- Certificate of conformity with applicable standards 5. Manufacturer quality control plan									

General Description 2

2 1603605059 36W Led Lighting Panel

100.000 EA 23010455 OR

General Description 1

161091 T8 led tube lamp glass
200-240VAC, 50HZ
cool white color 6000K, lifespan: 25000 hours
The lamps shall be compatible to be installed on old fluorescent lighting fixtures without removing the ballasts (plug and play mode)
Cap-base : G13 [medium Bi-Pin to replace fluorescent lamps]
Lamps shall be operated without starters
phase from one side and nutlral from other side
TUV, CE marking, ROHS compliance
Warranty : 3 years.

General Description 2

3 1603605068 GLASS LED TUBE LAMP, 120 CM, 1850 LM

500.000 EA 23010455 OR

General Description 1

160223 HEAVY DUTY EXPLOSION PROOF, PORTABLE LED
LIGHTING FIXTURE FACTORY SEALED,
COMPLETE WITH CABLE GLAND, SAFEGUARD

Jordan Petroleum Refinery Company
Quote Order

Order Number 23010287 OQ 00001

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Unit Price	Supplier Offer Currency Code	Original Order No	Type	Lin
AND INTEGRAL HANDLE FOR EASY PORTABILITY. THE LIGHTING FIXTURE TO BE SUITABLE FOR 50VAC POWER SUPPLY IT SHOULD BE SUITABLE FOR USE IN HAZARDOUS AREA ZONE 1, IIC, T3 ACCORING TO IEC 60079 . - LUMINOUS FLUX: 5000LM (MIN) - LUMINOUS EFFICIENCY: 130 LM /W - BEAM ANGLE > /= 120 DEGREE - 10% DRIVERS SHALL BE PROVIDED AS SPARE NOTE: LATEST EDITION OF EU-TYPE EXAMINATION CERTIFICATE ISSUED FROM A NOTIFIED BODY AND EU- CERTIFICATE OF CONFORMITY AND MANUFACTURER QUALITY CONTROL PLANE SHALL BE PROVIDED.											
General Description 2											

4	1603610003	PORTABLE EX.LED. LIGHT.	FIXTURE 50V		100.000	EA				23010455	OR
---	------------	-------------------------	-------------	--	---------	----	--	--	--	----------	----

General Description 1	161062	Explosion proof LED lighting fixture. Rated power: 25W Voltage range : 90-264VAC, frequency : 50HZ Marking : Ex II 2G Exd IIC T4 Gb Cable entries : 3/4 inch NPT threaded, IP55 Operating temperature : -10 to +45 °C Service life : >50000 hour, Color temperature : COOL light, clear glass. Luminous efficiency : >120 lm/W, Luminous flux>3000 Lm Power factor : >0.95, THD : <15%, Beam angle>120 Degree. Standards : IEC 60079-0, IEC 60079-1, IEC 60079-31. Dimensions : circular max. diameter 250 mm, square max. 250X250 mm Each fixture shall be provided complete with driver, ATEX certified connection box three entry and ATEX certified male-female nipple for ceiling type installation. manufacturer shall provide 10% drivers as spare at order quantity . The warranty period for the fixtures shall be not less than five years. Manufacturer shall be provide the following documents with his offer : 1. Tests reports explain the lux reading for 3mtr and 4mtr height. 2. Technical data sheet including dimensions 3. Installation and maintenance instructions. 4. EU-Type examination certificate according ATEX Directive 2014/34/EU for the fixture , connection and nipple. 5. EU Certificate of conformity with applicable standards 6. Manufacturer quality control plan To be used in hazardous areas , ZONE 1 , IIC , T4
-----------------------	--------	---

General Description 2

Jordan Petroleum Refinery Company
Quote Order

Order Number 23010287 OQ 00001

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Unit Price	Supplier Offer Currency Code	Original Order No	O Type
5	1603605058	25W EXPLOSION PROOF LED LIGHTING			200.000	EA			23010455	OR

General Description 1 161069 LED Explosion proof lighting fixtures
Voltage range : 90-264VAC
Rated frequency : 50HZ
Max.Power : 45 W
Marking : Ex II2GD Exd IIC T6 Gb Ex tb IIIC T80 °C Db
Cable entries : 3/4 inch NPT threaded .
Ingress protection : IP66
Operating temperature : -40 to +50 °C
Service life : >50000 hour.
Color temperature : COOL WHITE , 6500K .
Luminous efficiency : >130 Lm/W.
Power factor : >0.95
Luminous flux>5500 Lm.
THD : <15%.
Beam angle: 140 Degree.
Standards : IEC 60079-0, IEC 60079-1, IEC 60079-31.
Each fixture shall be provided complete with driver, explosion proof Three entry connection box and explosion proof male-female nipple for ceiling type installation.
Sample Shall Be Provided For Test

- The warranty period for the fixtures shall be not less than five years.
Manufacturer shall provide the following documents with his offer :
1. Tests reports explain the lux reading for 3mtr and 4mtr height.
 2. Technical data sheet including dimensions
 3. Installation and maintenance instructions.
 4. EU- Type examination certificate for the fixture , connection box and nipple.
 5. EU-Certificate of conformity with applicable standards
 6. Manufacturer quality control plan

General Description 2

6	1604019050	Explosion proof led lighting,	Exd IIC T6	150.000	EA				23010455	OR
---	------------	-------------------------------	------------	---------	----	--	--	--	----------	----

Jordan Petroleum Refinery Company
Quote Order

Order Number 23010287 00001

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Unit Price	Supplier Offer Currency Code	Original Order No	Type	Q Lin
Purchasing Manager :											

Remarks of Purchasing Department :

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Unit Price	Supplier Offer Currency Code	Original Order No	Type	O Lin
-------------	-----------------	-------------	----------------	-------------------	---------------------	------	------------------------------	---------------------------------	----------------------	------	----------