



شركة مصفاة البترول الاردنية المساهمة المحدودة عمان - الأردن

مناقصة رقم (129 / 2023) مستودع (23010850) Mobile Monitor Foam Unit.

الموضوع :- دعوة للاشتراك في مناقصة محلية

ترغب شركة مصفاة البترول الاردنية بشراء المواد المبينة تفاصيلها ومواصفاتها الفنية في الكشف المرفق وباعتباركم مورداً لهذه المواد نوجه هذه الدعوة لكم للاشتراك بالمناقصة اعلاه وتقديم عرض سعر للمواد المطلوبة اذا وجدتم ان بإمكانكم تنفيذه مع الالتزام بكافة الشروط والمواصفات وفيما يلي الشروط العامة للمناقصة :-

1. يقدم العرض (نسختين) قبل الموعد المحدد ادناه ضمن ظرف مغلق ومختوم مبينا عليه رقم المناقصة وتاريخ الاغلاق واسم وعنوان المناقص ويسلم باليد الى (دائرة المشتريات الإدارة العامة - جبل عمان - الدوار الأول) ولا يقبل اي عرض يرسل بالفاكس نهائياً .
2. يجب ان يكون العرض مروساً باسم وعنوان المورد موقعا ومختوما بالخاتم الرسمي للمناقص ومرفقا بصورة الشروط موقعة ومختومة منه لتأكيد التزامه بكافة الشروط والمواصفات وكذلك تقديم نسخة من السجل التجاري ورخصة المهن .
3. على المناقص تثبيت الاسعار الافرازية والاجمالية على عرضه رقما وكتابة بخط واضح دون تصحيح او كشط او محو .
4. على المناقص بيان الامور التالية في عرضه بوضوح :-
 - شمول السعر لضريبة المبيعات 16% او اية نسبة تحدد بعرض السعر والرسوم الجمركية .
 - في حال وجود اي خدمة اضافية يراد تقديمها في العرض وغير واردة في مواصفات طلب المواد او امر الشراء يجب ان يتم ذكرها بالتفصيل وان يتم بيان كلفتها المالية بشكل واضح .
 - مدة صلاحية الاسعار (يجب الاتقل عن (90) يوم من تاريخ تقديم العرض وخلاف ذلك يحق للمصفاة استبعاد العرض) .
 - اجور النقل الى مستودعاتنا في الزرقاء يجب ان تكون مشمولة ضمن السعر المعروض .
 - ان تكون المواد المعروضة جديدة وغير مستعملة او مجددة وخالية من العيوب مع بيان سنة الصنع .
 - ان يحدد منشأ البضاعة والالتزام بتقديم شهادة بلد المنشأ وتحديد اسم الشركة الصانعة، مده التوريد، مكان التسليم علما ان مكان التسليم مستودعاتنا في (الزرقاء) العروض المتضمنة تسليم CFR AQABA او CPT QAIA غير مقبولة.
 - تثبيت السعر الافرازي والاجمالي رقما وكتابه بخط واضح دون شطب او تعديل.
5. على المناقص تقديم شهادة منشأ عند توريد المواد (مصدقة اصولا او تشير للبيان الجمركي)
6. الشركة غير ملزمة بالإحالة على اقل الاسعار ويحق لها رفض اي عرض دون ابداء الاسباب.
7. يحق للشركة الغاء المناقصة او اعادة طرحها او شراء جزء منها او التعديل على الكميات المطلوبة دون بيان الاسباب ودون ان تتحمل اي مسؤولية أياً كان نوعها.

8. على المناقص عدم مراجعة اي جهة فنية في الشركة الا بالتنسيق مع دائرة المشتريات.
9. المواد المطلوبة خاضعة للزيادة والنقصان بنسبة $\pm 25\%$. ☒
10. يلتزم المناقص بقبول الإحالة الجزئية. ☒
11. يلتزم المناقص بتقديم عينات حسب القياس المطلوب وشهادات الفحص المبينة في الشروط المرفقة او كتالوجات لأي من البنود المطلوبة مع العرض.
12. يلتزم المناقص بدفع قيمة طابع الواردات والبالغة (6) بالاف على قرار الاحالة خلال عشرة ايام من تبليغه بالقرار.
13. على المناقص تقديم كفالة حسن تنفيذ غير مشروطة بنسبة 10% من القيمة الاجمالية (بعد الاحالة) لحين استلام المواد والموافقة عليها.
14. يتم دفع ثمن المواد المشتراه بعد استلام المواد في مستودعات الشركة وبعد صدور سند استلام يؤكد استلامها كاملة ومطابقة للشروط والمواصفات.
15. في حال تأخير توريد / تنفيذ المناقصة حسب ما تم الاتفاق عليه يترتب عليكم غرامة قدرها (20) دينار اردني عن كل يوم تأخير .
16. في حال اخلال المتعهد المحال عليه المناقصة باي من التزامات, يحق للشركة الغاء الاحالة واللجوء الى طرف ثالث دون الحاجة لأي اخطار او انذار عادي او عدلي ودون الحاجة لمراجعة القضاء وتحمل المتعهد كافة التكاليف المترتبة على ذلك
17. تعتبر هذه الشروط جزءاً لا يتجزأ من المناقصة وعلى المورد الالتزام بما جاء فيها.
18. اخر موعد لقبول واستلام العروض الساعة الثالثة من ظهر يوم الخميس الموافق 2023/10/05 وتسلم لدائرة المشتريات - الادارة العامة - جبل عمان - الدوار الأول - الطابق الأول - مكتب 10
19. في حال وجود أي استفسار يتم إرساله بالبريد الإلكتروني على العنوان (Purchasing@jopetrol.com.jo) .
20. يجب ان تكون الفاتورة المقدمة من قبلكم في حال شراء السلع او تقديم خدمة وفقا " لنظام تنظيم شؤون الفوترة والرقابة عليها رقم (34) لسنة 2019 وسيتم رفض أي فاتورة لا تكون وفقا " للنظام أعلاه .
21. الالتزام بأمر الدفاع 11 أثناء مراجعة دوائر شركة مصفاة البترول.
- كما يشترط تقديم البيانات التالية على الفواتير الصادرة من قبلكم :-
- الاسم الكامل للشخص أو الشركة أو المفوض بالتوقيع وختم الشركة الرسمي او المفوض بالتوقيع وتوقيعه.
- الرقم الوطني الكامل للشخص أو الشركة أو المفوض بالتوقيع .
- العنوان الكامل بالإضافة إلى رقم الهاتف والصندوق البريدي والرمز البريدي .
- الرقم لضريبي للشخص أو الشركة إن وجد .
- ☒ غير مطلوبة

Jordan Petroleum Refinery Company
Quote Order

Order Number 23010472 OQ 00001

Delivery Instructions

Branch/Plant 2002
Order Date 08/08/2023
Request Date 29/02/2024
Freight Handling

General Description 1	190346	FIREFIGHTING MOBILE MONITOR FOAM UNIT, WITH THE FOLLOWING SPECIFICATIONS :- * THE MOBILE MONITOR FOAM UNIT SHALL MEET THE REQUIREMENTS OF NFPA 11. * THE MOBILE MONITOR FOAM UNIT SHALL HAD CERTIFICATE OF TYPE APPROVAL (FM / UL LISTED OR HAD A CERTIFICATE APPROVAL FROM AUTHRIEZED LAB). * TO BE USED WITH LOW EXPANSION FOAM TYPE AR-FFF 3% X 3%. * TO BE USED WITH FIRE FIGHTING DIA.2.1/2" FIRE HOSE OR GLOBE VALVE. * ALL INSTANTANEOUS COUPLING USED IN THE PORATBLE FOAM BRANCH PIPE AND MOBILE FOAM UNIT MANUFACRING ACCORDING TO EN 336 WITH A CIRTIFACTE APPROVAL TYPE FROM AUTHRIEZED LAB & GUNMETAL MATERIAL. OPERATING/WORKING PRESSURE: NOT LESS THAN 7 BARS. * SHUT OFF (GLOBE OR BALL) VALVE. * SELF-INDUCING OPTIONS WITH QUICK COUPLING * FOAM TANK MANUFACTURED FROM CHEMICALLY RESISTANT AND IS FITTED WITH A 'QUICK-FILL' TWIST OFF FILLER CAP EASILY LOCATED ON THE TOP OF THE TANK. * CAPACITY OF MOBILE FOAM UNIT: 500 LITERS AS PER DEMAND OR EQUIVALENT. * AN INTEGRAL SUPPORT ARM STABILIZES MOBILE MONITOR FOAM UNIT, WHEN STATIONARY. * FITTED WITH SOLID RUBBER TIRES IMPERVIOUS TO PUNCTURES MAKING MOBILE MONITOR FOAM UNIT AN 'ALL-TERRAIN' UNIT SUITABLE FOR USE ON ROUGH GROUND AND FOR MANEUVERING OVER OBSTACLES OR EQUIVALENT. * CORROSION RESISTANT PLASTIC COATED FRAME (HANDLE AND CHASSIS) OR EQUIVALENT. * MANUFACTURERS SHALL PROVIDE WITH THEIR OFFERS THE FOLLOWING: - FULL TECHNICAL DATA SHEET OF MOBILE MONITOR FOAM UNIT. - WEIGHT OF MOBILE MONITOR FOAM UNIT. - MINIMUM & MAXIMUM WORKING PRESSURE. - THROW DISTANCE. - MAXIMUM FLOW RATE. - MATERIAL OF MOBILE MONITOR FOAM UNIT. - DIMENSIONS OF MOBILE MONITOR FOAM UNIT. - TABLE OF COMPLIANCE * MOUNTED WITH FOAM MONITOR AND FOAM NOZZEL ACCORDING TO THE FOLLOWING SPECIFICATIONS: 1- MONITOR SPECIFICATIONS:- - MANUAL CONTROL MONITOR WITH LEVER HANDLE. - FRICTION LOCK ON BOTH VERTICAL AND HORIZONTAL TRAVELS.
-----------------------	--------	---

Jordan Petroleum Refinery Company
Quote Order

Order Number 23010472 OQ 00001

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Unit Price	Supplier Offer Currency Code	Original Order No	Orig Type	LineNo
- POSITIVE LOCKING CONTROLLER AND GREASE FITTINGS FOR LUBRICATION. - MOVEMENT: HORIZONTALLY: 360 DEG VERTICALLY: (-) 60 DEG. TO (+) 90 DEG. - INLET CONNECTION: 4" ASME FLANGED, RF, CLASS 150 - OUTLET CONNECTION: 2.1/2 " BSP MALE THREADED. - MAX. FLOW RATE OF UP TO 1250 GPM (4800 LPM) AT 7 KG/CM2 WATER PRESSURE. - MINIMUM DISCHARGE RANGE (m) AT 45 DEG. NOT LESS: 60 m - MATERIAL OF CONSTRUCTION: BRASS. - DESIGN PRESSURE: 16 KG/CM2. - MAXIMUM PRESSURE MUST BE PROVIDED AND NOT LESS THAN: 16 KG / CM2. - TEST PRESSURE: 24 KG / CM2. - RED POWDER COATED OUTSIDE (RAL 3000) - SUITABLE FOR USE WITH FRESH & SEA WATER. - TENDERERS SHALL PROVIDE WITH HIS OFFER THE FOLLOWING: * CROSS SECTIONAL DRAWING WITH SPARE PARTS LIST FOR MONITOR. * HYDROSTATIC TEST PRESSURE CERTIFICATE. * CERTIFICATE OF TYPE APPROVAL (FM APPROVED OR UL LISTED) * CHARACTERISTIC CURVE OF MONITOR. * FULL TECHNICAL DATA SHEET. - MONITOR MUST SUPPLY WITH WATER / FOAM NOZZEL AND COMPITABLE WITH SELF-EDUCTION FOAM NOZZEL AS BELOW NOZZEL SPECIFICATIONS:- 2- NOZZEL SPECIFICATIONS:- - HYDRO-FOAM NOZZLE WITH FOAM TYPE AR-FFF FOAM - FOAM RATIO (1% TO 6%), INTERCHANGEABLE FOAM ORIFICE INSERTS ENABLE VARIABLE FOAM PROPORTIONING (FOAM METERING WASHERS MUST BE PROVIDED). - DESIGNED FOR USE WITH FOAM TYPE AR-FFF FOAM. - MATERIAL: HEAVY-DUTY CORROSION RESISTANT BRASS CONSTRUCTION. - NOZZLE INLET: 2.1/2" (65 MM) BSP THREADS AND SWIVEL CONNCTION. - 1.1/2" ISOLATION VALVE FOR SHUTOFF CAPABILITY AT FOAM INLET & QUICK CONNECTIONCOUPLING WITH 1.1/2" PICK UP PVC TUBE WITH INTERNAL SPIRAL STEEL REINFORCEMENT AND S.S. DIP TUBE. - NOZZLE FLOW RANGE 350 TO 750 GPM (1325 TO 2900 LPM) @ 7 KG/CM2 WATER PRESSURE. - SUITABLE TO FOR USE WITH FRESH & SEA WATER. - SELF- EDUCTION. - TENDERERS SHALL PROVIDE WITH HIS OFFER THE FOLLOWING: * OPERATING & MAINTENANCE INSTRUCTION. * CHARACTERISTIC CURVE OF NOZZLE. * CROSS SECTION DRAWING. * CERTIFICATE OF TYPE APPROVAL (FM APPROVED OR UL LISTED)											
General Description 2											

Jordan Petroleum Refinery Company
Quote Order

Date 08/08/2023
Page - 2

Order Number 23010472 00001

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Unit Price	Supplier Offer Currency Code	Supplier Offer Order No	Original Order No	Orig Type	LineNo
----------	--------------	-------------	-------------	----------------	------------------	------	---------------------------	------------------------------	-------------------------	-------------------	-----------	--------

Purchasing Manager :

Remarks of Purchasing Department :

.....
.....