



شركة مصفاة البترول الاردنية المساهمة المحدودة

عمان - الأردن

مناقصة: رقم (162 / 2025) طلب المواد رقم (OQ25010581) (لوازم كهربائية)

الموضوع: - دعوة للاشتراك في مناقصة محلية

ترغب شركة مصفاة البترول الاردنية بشراء المواد المبينة تفاصيلها ومواصفاتها الفنية في الكشف المرفق وباعتباركم مورداً لهذه المواد نوجه هذه الدعوة لكم للاشتراك بالمناقصة اعلاه وتقديم عرض سعر للمواد المطلوبة مع الالتزام بكافة الشروط والمواصفات المطلوبة، وفيما يلي الشروط العامة للمناقصة: -

1. تقديم عرض الأسعار على (نسختين) قبل الموعد المحدد لإغلاق المناقصة ضمن ظرف مغلق ومختوم مبينا عليه رقم المناقصة وتاريخ الاغلاق واسم وعنوان المناقص ويسلم باليد الى (دائرة المشتريات الإدارة العامة - جبل عمان - الدوار الأول) ولا يقبل اي عرض يرسل بالفاكس نهائياً.
2. يجب ان يكون عرض الاسعار مروس باسم وعنوان المورد موقعاً ومختوماً بالخاتم الرسمي للمناقص ومرفقاً بصورة الشروط موقعة ومختومة لتأكيد التزامكم بكافة الشروط والمواصفات وكذلك تقديم صورة من السجل التجاري ورخصة المهن سارية المفعول.
3. على المناقص تثبيت الاسعار الافردية والاجمالية في عرض الاسعار رقماً وكتابة بخط واضح دون تصحيح او كشط او محو او تعديل.
4. على المناقص بيان الشروط التالية في عرض الأسعار وبشكل واضح: -
 - شمول السعر لضريبة المبيعات 16% او اية نسبة تحدد بعرض السعر والرسوم الجمركية.
 - في حال وجود اي خدمة اضافية يراد تقديمها في العرض وغير واردة في مواصفات طلب المواد او امر الشراء يجب ان يتم ذكرها بالتفصيل وان يتم بيان كلفتها المالية بشكل واضح.
 - مدة صلاحية الأسعار يجب الا تقل عن (60) يوم من تاريخ اغلاق المناقصة وخلاف ذلك يحق لشركة مصفاة البترول استبعاد العرض.
 - اجور النقل الى مستودعاتنا موقع المصفاة الزرقاء .
 - ان تكون المواد المعروضة جديدة وغير مستعملة او مجددة وخالية من العيوب مع بيان سنة الصنع.
 - تحديد منشأ البضاعة والالتزام بتقديم شهادة بلد المنشأ عند توريد المواد (مصدقة اصولاً او تشير للبيان الجمركي) وتحديد اسم الشركة الصانعة، مده التوريد، مكان التسليم
5. الشركة غير ملزمة بالإحالة على اقل الاسعار ويحق لها رفض اي عرض دون ابداء الاسباب.

اسم

اسم

اسم



شركة مصفاة البترول الاردنية المساهمة المحدودة

عمان - الأردن

6. يحق للشركة الغاء المناقصة او اعادة طرحها او شراء جزء منها او التعديل على الكميات المطلوبة دون بيان الاسباب ودون ان تتحمل اي مسؤولية أياً كان نوعها.
7. على المناقص عدم مراجعة اي جهة فنية في الشركة الا بالتنسيق مع دائرة المشتريات.
8. المواد المطلوبة خاضعة للزيادة والنقصان بنسبة $\pm 25\%$.
9. على المناقص الالتزام بقبول الإحالة الجزئية.
10. على المناقص الالتزام بتقديم عينات مجانية للمواد المعروضة في حال طلبها حسب ما هو مطلوب وشهادات الفحص المبينة في الشروط المرفقة او كتالوجات لأي من البنود المطلوبة مع العرض.
11. على المناقص الالتزام بدفع قيمة طوابع الواردات والبالغة (6) بالآلف على قرار الاحالة خلال عشرة ايام من تبليغه بقرار الإحالة.
12. على المناقص تقديم كفالة حسن تنفيذ غير مشروطة بنسبة 10% من القيمة الاجمالية بعد تبليغه بقرار الاحالة تبقى سارية المفعول لحين استلام المواد والموافقة عليها.
13. يتم دفع ثمن المواد المشتراة بعد استلام المواد في مستودعات الشركة وبعد صدور سند استلام يؤكد استلامها كاملة ومطابقة للشروط والمواصفات.
14. في حال تأخير توريد او تنفيذ المناقصة حسب ما تم الاتفاق عليه يترتب عليكم غرامة قدرها (20) دينار أردني عن كل يوم تأخير على ان لا تتجاوز 5% من قيمة الإحالة.
15. في حال اخلال المتعهد المحال عليه المناقصة باي من الالتزامات، يحق للشركة الغاء الاحالة واللجوء الى طرف ثالث دون الحاجة لأي اخطار او انذار عادي او عدلي ودون الحاجة لمراجعة القضاء وتحميل المتعهد كافة التكاليف المترتبة على ذلك.
16. إذا عجز المورد المحال عليه المناقصة عن التوريد أو تأخر في تقديم كمية من أصل المناقصة أو عجز عن تقديم أية كمية في وقتها المحدد أو إذا ثبت أن أحد المناقصين قدم للشركة لوازماً أو قام بأداء خدمات بطرق الغش، لشركة مصفاة البترول الحق بما يلي:
 - مصادرة كفالة حسن التنفيذ المقدمة للمناقصة أو جزء منها، وقيد المبلغ المصادر إيراداً لحساب الشركة.
 - القيام بشراء اللوازم من الأسواق المحلية أو الأجنبية بالأسعار الرائجة والرجوع على المناقص بفرق السعر وخضم ذلك من الكفالة ، أو إحالة المناقصة او جزء منها على السعر الذي يليه مع تحميل المستكشف فرق السعر
 - حرمان المناقص من الدخول في العطاءات/ المناقصات للمدة التي تراها الشركة مناسبة.
17. تعتبر هذه الشروط جزءاً لا يتجزأ من المناقصة وعلى المورد الالتزام بما جاء فيها.

السيد

السيد



شركة مصفاة البترول الاردنية المساهمة المحدودة

عمان - الأردن

18. اخر موعد لقبول واستلام العروض الساعة الرابعة من ظهر يوم الخميس **2025/12/18** وتسلم لدائرة المشتريات - الادارة العامة - جبل عمان - الدوار الأول -الطابق الأول - مكتب 10
 19. في حال وجود أي استفسار يتم إرساله بالبريد الإلكتروني على العنوان (Local.Purchasing@jopetrol.com.jo).
 20. يجب ان تكون الفاتورة المقدمة من قبلكم في حال شراء السلع او تقديم خدمة وفقا" لنظام تنظيم شؤون الفوترة والرقابة عليها رقم (34) لسنة 2019 وسيتم رفض أي فاتورة لا تكون وفقا" للنظام أعلاه.
- كما يشترط تقديم البيانات التالية على الفواتير الصادرة من قبلكم: -
- الاسم الكامل للشخص أو الشركة أو المفوض بالتوقيع وختم الشركة الرسمي او المفوض بالتوقيع وتوقيعه.
- الرقم الوطني الكامل للشخص أو الشركة أو المفوض بالتوقيع.
- العنوان الكامل بالإضافة إلى رقم الهاتف والصندوق البريدي والرمز البريدي.
- الرقم الضريبي للشخص أو الشركة إن وجد.

س

س

Jordan Petroleum Refinery Company
Quote Order

Order Number 25010581 OQ 00001

Delivery Instructions

Branch/Plant 2002
Order Date 24/11/2025
Request Date 29/05/2026
Freight Handling

General Description 1 161099 Surface Mounting LED lighting panel
Dimensions : square 600X600 mm
Voltage range : 100-270VAC
Rated frequency : 50HZ
Rated power: 36W
Ingress protection : IP42
Operating temperature : -5 to + 45 °C
Service life : >50000 hour.
Color temperature : 6000-6500K (cool white) .
Luminous efficiency : >90 lm/W.
Power factor : >0.95
Luminous flux>3600 Lm.
THD : <15%.
Beam angle>120 Degree.
Warranty : 5 years for fixtures and drivers .
Each fixture shall be provided complete with good quality driver and Surface mounted frame used to fix the panel light on the wall.
Manufacturer shall be provide the following documents with his offer :
1. Tests reports explain the lux reading for 3mtr and 4mtr height.
2. Technical data sheet including dimensions
3. Installation and maintenance instructions.
4. EU- Certificate of conformity with applicable standards
5. Manufacturer quality control plan

General Description 2

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Supplier Offer Unit Price	Supplier Offer Currency Code	Original Order No	Orig Type	LineNo
1	1603605070	SURFACE MOUNTING LED LIGHTING PANEL 600X600 mm			50.000 EA			25011140	OR	1

General Description 1 160348 KILOWATT HOUR METER 3 PHASE 3 WIRE/4 WIRE UNBALANCED LOAD, 380V, 50HZ.5AMP

3

Jordan Petroleum Refinery Company
Quote Order

Date 24/11/2025
Page - 2

Order Number 25010581 OQ 00001

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Unit Price	Supplier Offer Currency Code	Original Order No.	Orig Type	LineNo
General Description 2											
2	1603670005	8KILOWATT HOUR METER 3 PHASE, 380V.5AMP.				3,000 EA			25011140 OR		2

General Description 1 160167 CONVENIENCE SOCKET OUTLETS COMPLETE WITH DOUBLE POLE SWITCH AND EXTERNAL EARTH TERMINAL .
THE EXTERNAL EARTH TERMINAL SHALL BE SUITABLE FOR 35 SQ. MM. EARTH CABLE
OUTLET TO BE FULLY INTERLOCKED SO THAT PLUG CAN ONLY BE WITHDRAWN WHEN SWITCH IS IN THE "OPEN" POSITION. TO BE SUPPLIED WITH SCREWED CAP OR SPRING LOADED HINGED FLAP FOR SOCKET PROTECTION
SOCKET TO BE WEATHERPROOF IP 55 AT LEAST.

General Description 2

3	1603690042	SOCKET 3P.+N+EARTHING.63A.6H /380-415 V AC				3,000 ST			25011140 OR		3
---	------------	--	--	--	--	----------	--	--	-------------	--	---

General Description 1 160198 IGNITION MODULE in ATEX certified enclosure
Input Voltage: 230 Vac 50 Hz
Output Voltage: 10000 Vdc
Spark frequency: 2 sparks / s
Output energy:18 J / spark
Suitable to flare ignition for the disposal of process gas in refineries.
Suitable to operate in potentially explosive atmospheres, Zone 1 (Exd II CT4, IP56).
Suitable for outdoor installation
Push button on the panel to start ignition
Complete with ignition cables and spark plug
The following documents shall be provided with offer:
1. Technical specifications and dimensional Drawing
2. EU type examination certificate issued from notified body
3. EU declaration of conformity with applicable standards
You can order from the following companies:

Jordan Petroleum Refinery Company
Quote OrderDate 24/11/2025
Page - 3

Order Number 25010581 OQ 00001

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Price	Supplier Offer Currency	Order No	Type	Line No	Orig
1-NATIONAL AIR OIL BURNER CO.												
2-NU-WAY Enertech Group												
3-BRAHMA system & components for heating												
4-TESI Sparking, Running, Protecting Energy												
5- Tectiko Equipment Solutions												
6-Allanson International Inc.												
General Description 2												
4	1603755004	IGNITION TRANSFORMER		(250 VA)		1.000 EA			25011208 OR		1	
General Description 1 160007 SINGLE CORE CABLES												
CONDUCTOR : STRANDED COPPER CONDUCTORS												
INSULATION : PVC(POLYVINYL CHLORIDE)												
VOLTAGE RATING : 450/750V												
TEMPERATURE RATING : 0 C TO 0+70 C												
CU/PVC												
STANDARDS: IEC 60227, BS 6004, BS EN 60228, BS7655, BS EN 50525-2-31												
NOTES:												
- TO BE SUPPLIED IN ONE COIL EACH 100 YARDS.												
- THE OFFER SHALL BE INCLUDE THE FOLLOWING:												
* TECHNICAL DATA SHEET(TDS)												
* LEAFLETS CATALOGUES												
* FACTORY TESTS												
General Description 2												
5	1601010019	CABLE PVC 6 SQ.MM BLUE				300.000 YD			25011204 OR		1	
6	1601010020	CABLE PVC 6 SQ.MM BLACK				300.000 YD			25011204 OR		2	

Quote Order

Order Number 25010581 OQ 00001

Line No.	VO CAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Price	Currency Code	Original Order No	Orig LineNo
General Description 1										
161132		Flash light alkaline batteries, primary disposable Energizer, Duracell, Panasonic, KODAK								
Note:										
* Manufacturing date shall be tapped on the battery.										
* Production date shall be less than nine months.										
* Sample shall be provided with offer.										
General Description 2										
7	1602230005	1.5 V. model no.LR03. size AAA			200.000	EA			25011202 OR	1
General Description 1										
161023		SPARE PARTS FOR FORCED DRAFT FAN OF BOILERS(7001&7002)								
SOFT STARTER TYPE ATS48C25Q,ALTISTART 48, SERIAL NO.: 8B1108114002, INPUT VOLTAGES : 220-415 VAC,50/60 HZ,800 MA, (ICI)NOMINAL CURRENT : 250A.										
General Description 2										
8	1603764080	SOFT STARTER ATS48C25Q.			1.000	EA			25011199 OR	1
General Description 1										
160049		MINIATURE CIRCUIT BREAKER DIN RAIL THREE POLE 380 VOLTS. 6KA R.C.								
General Description 2										
9	1602200035	MINIATURE C.B.3 POLE			15.000	EA			25011143 OR	1
General Description 1										
160356		SPARES FOR FUEL OIL AND NAPHTHA ADDITIONAL STORAGE TANKS, 90 KW.								

Order Number 25010581 OQ 000001

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Unit Price	Supplier Offer	Original Order No	Type	LineNo
General Description 2											
10	1602326026	AIR BREAKER CONTACTOR	220V(3TF5222-OAPO)		1.000 EA		25011143	OR			2
General Description 1 160032 ELECTRICAL ACCESSORIES. MANUF. : DAVICO INDUSTRIAL LTD. FAX: 0121-520 7775 REF.DRG.NO.: C-53630 & C-80641.											
General Description 2 160796 INSULATED PIN TERMINALS.											
11	1601066108	INSULATED PIN TERMINALS BLUE	VINYL.	DVP2-12	350.000 EA		25011143	OR			3
General Description 1 160045 MINIATURE CIRCUIT BREAKER DIN RAIL 230V, 50HZ.											
General Description 2 161047 MINIATURE CIRCUIT BREAKER 230V,32A, DOUBLE(1P+N)BREAKING CAPACITY 4.5KA, DIN-RAIL TYPE											
12	1602200013	MINIATURE CIRCUIT BREAKER 230V	30A,DOUBLE(1P+N)		30.000 EA		25011143	OR			4
General Description 1 160058 SPARES FOR REFINERY ELECTRICAL MOTOR CONTROL CENTER AND DISTRIBUTION PANELS MCC AND DB.											

Quote Order

Order Number 25010581 OQ 00001

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Price	Unit Price	Currency Code	Order No	Type	LineNo	Orig
General Description 2 161082 REF.DRG.NO. : C-29863-29903 LOCATION : 3RD. EXP. PROJECT SINGLE POLE CIRCUIT BREAKER 230V,1A BREAKING CAPACITY 4.5KA,DIN RAIL TYPE.													
13	1602201012	SINGLE POLE CIRCUIT BREAKER	230V,1A		10.000 EA					25011143	OR	5	
General Description 1 160424 SPARES FOR REFINERY ELECTRICAL MOTOR CONTROL CENTER AND DISTRIBUTION PANELS MCC AND DB REF.DRG.NO. : C-29863-29903 LOCATION : 3RD. EXP. PROJECT.													
General Description 2 160085 CURRENT TRANSFORMERS :- TO BE ORDERED FROM :- ITAL SERVICES & CONS.U.K. ITAL HOUSE THE OUADRANT 219 HATFIELD ROD.ST. ALBANS TEL.01727846969 FAX.01727 846702													
14	1602201383	CTS 600/5A, 10VA/0.5,TYPE	ADF-2E(RING)		3.000 EA					25011143	OR	6	
General Description 1 161028 CURRENT TRANSFORMER-RING TYPE 100/1, 5VA/0.5 MAX.VOLTAGE 600 V ,FREQ 50/HZ. ACCURACY CLASS 0.5,BASES FOR BACK PLATE INTERNAL DIAMETER MAX 32 MM.													

Jordan Petroleum Refinery Company
Quote Order

Date 24/11/2025
Page - 7

Order Number 25010581 OQ 00001

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Unit Price	Supplier Offer Currency Code	Original Order No	Orig LineNo
OUTER DIAMETER MAX 70 MM THICKNESS 73 MM										
15	1602201377	CURRENT TRANSFORMER-RING TYPE 100/1,5VA/0.5			6.000	EA			25011143 OR	7
General Description 1 161161 DC Miniature Circuit Breaker Din Rail. Suitability for industrial isolation according to IEC/EN 60947-2 standard Combine short-circuit and overload currents protection Application: For use in DC distribution panels Rated operational voltage: 220 VDC Rated insulation voltage: 500 V DC rated impulse withstand voltage: 6 kV Rated breaking capacity: 20 kA Icu at 220 V DC. Tripping characteristic: Thermal-Magnetic, Curve C Number of poles: 2P Shall be provide the following: 1- Technical catalogues and datasheets. 2- Test certificates proving compliance with IEC standards. Warranty period: not less than 12 months from delivery.										
General Description 2										
16	1602204001	DC Miniature Circuit Breaker,	1A		100.000	EA			25011143 OR	8
17	1602204005	DC Miniature Circuit Breaker,	5A		50.000	EA			25011143 OR	9
18	1602204010	DC Miniature Circuit Breaker,	10A		10.000	EA			25011143 OR	10
19	1602204016	DC Miniature Circuit Breaker,	16A		10.000	EA			25011143 OR	11
20	1602204020	DC Miniature Circuit Breaker,	20A		10.000	EA			25011143 OR	12
21	1602204025	DC Miniature Circuit Breaker,	25A		10.000	EA			25011143 OR	13

Order Number 25010581 OQ 000001

Line No.	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Unit Price	Supplier Offer	Currency Code	Original Order No	Type	LineNo
22	1602204002	DC Miniature Circuit Breaker,	2A		50.000	EA				25011143	OR	14
23	1602204003	DC Miniature Circuit Breaker,	3A		50.000	EA				25011143	OR	15
General Description 1		160094	MITSUBISHI NO FUSE AIR CIRCUIT BREAKER 380 VOLTS THREE POLES WITH THERMAL RELAY .									
General Description 2		160947	SPECIFICATION - MITSUBISHI MOLDED CASE CIRCUIT BREAKER - TYPE NF 100-SP,T/A - RATING (100)AMP - THERMAL ADJUSTABLE RANG (80-100)AMP.									
24	1602205011	MITSUBISHI MOLDED CASE CIRCUIT BREAKER TYPE NF 100-SP T/A			5.000	EA				25011143	OR	16
General Description 1		160299	HIGH IMPACT PLASTIC CABLE TRUNK COMPLETE WITH COVER SUITABLE FOR ELECTRICAL INSTALLATIONS. COVER IS TO BE CLIP-ON LID FOR SECURITY AND EASILY REMOVABLE WITH STANDARD DEPTH ACCORDING TO BS 4678 PART 4, STANDARD LENGTH 3 METERS .									
General Description 2												
25	1604016002	PLASTIC CABLE TRUNK COMPLETE	DIM 25X16MM		504.000	M				25011147	OR	17

Jordan Petroleum Refinery Company
Quote Order

Order Number 25010581 OQ 00001

Line No	VOCAB Number	Description	Part Number	Drawing Number	Ordered Quantity	Unit	Supplier Offer Unit Price	Supplier Offer Currency Code	Original Order No	Original Type	Orig LineNo
26	1601060030	PLASTIC CABLE			1500.000	EA			25011147	OR	2
		TIES 20CM LENGTH									

Purchasing Manager :

Remarks of Purchasing Department :
.....
.....

OR No. (25011140), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
Item (1)	
Surface Mounting LED lighting panel	
Dimensions : square 600X600 mm	
Voltage range : 100-270VAC	
Rated frequency : 50HZ	
Rated power: 36W	
Ingress protection : IP42	
Operating temperature : -5 to + 45 °C	
Service life : >50000 hour.	
Color temperature : 6000-6500K (cool white) .	
Luminous efficiency : >90 lm/W.	
Power factor : >0.95	
Luminous flux>3600 Lm.	
THD : 120 Degree.	
Warranty : 5 years for fixtures and drivers .	
Each fixture shall be provided complete with good quality driver and Surface mounted frame used to fix the panel light on the wall.	
Qty (50) EA	

OR No. (25011140), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
Item (2)	
KILOWATT HOUR METER 3 PHASE 3 WIRE/4 WIRE UNBALANCED LOAD, 380V, 50HZ,5AMP	
Qty (3) EA	

OR No. (25011140), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
Item (3)	
CONVENIENCE SOCKET OUTLETS COMPLETE WITH DOUBLE POLE SWITCH AND EXTERNAL EARTH TERMINAL .	
THE EXTERNAL EARTH TERMINAL SHALL BE SUITABLE FOR 35 SQ. MM.	
EARTH CABLE OUTLET TO BE FULLY INTERLOCKED SO THAT PLUG CAN ONLY BE WITHDRAWN WHEN SWITCH IS IN THE "OPEN" POSITION.	
TO BE SUPPLIED WITH SCREWED CAP OR SPRING LOADED HINGED FLAP FOR SOCKET PROTECTION.	
SOCKET TO BE WEATHERPROOF IP 55 AT LEAST.	
SOCKET 3P.+N+EARTHING,63A,6H /380~415 V AC	
Qty (3) ST	

OR No. (25011208), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
Item (1)	
IGNITION MODULE in ATEX certified enclosure	
Input Voltage: 230 Vac 50 Hz	
Output Voltage: 10000 Vdc	
Spark frequency: 2 sparks / s	
Output energy:18 J /	
spark Suitable to flare ignition for the disposal of process gas in refineries.	
Suitable to operate in potentially explosive atmospheres, Zone 1 (Exd II CT4, IP56).	
Suitable for outdoor installation	
Push button on the panel to start ignition	
Complete with ignition cables and spark plug	
IGNITION TRANSFORMER (250 VA)	
Qty (1) EA	

OR No. (25011204), OQ No. ()

(Each point must be confirmed/commented upon and must be submitted with the offer)

Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
SINGLE CORE CABLES CONDUCTOR : STRANDED COPPER CONDUCTORS INSULATION : PVC(POLYVINYL CHLORIDE) VOLTAGE RATING : 450/750V TEMPERATURE RATING : 0 C TO 0+70 C CU/PVC STANDARDS: IEC 60227, BS 6004, BS EN 60228, BS7655, BS EN 50525-2-31 NOTES: - TO BE SUPPLIED IN ONE COIL EACH 100 YARDS. - THE OFFER SHALL BE INCLUDE THE FOLLOWING: * TECHNICAL DATA SHEET(TDS) * LEAFLETS CATALOGUES * FACTORY TESTS	
Item (1): CABLE PVC 6 SQ.MM BLUE Qty (300)YD	
Item (2): CABLE PVC 6 SQ.MM BLACK Qty (300)YD	

OR No. (25011202), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
Flash light alkaline batteries, primary disposable Energizer, Duracell, Panasonic, KODAK Note: * Manufacturing date shall be tapped on the battery. * Production date shall be less than nine months. * Sample shall be provided with offer.	
Item (1): 1.5 V, model no.LR03, size AAA Qty (200)EA	

OR No. (25011199), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
SPARE PARTS FOR FORCED DRAFT FAN OF BOILERS(7001&7002) SOFT STARTER TYPE ATS48C25Q,ALTISTART 48, SERIAL NO.: 8B1108114002, INPUT VOLTAGES : 220-415 VAC,50/60 HZ,800 MA, (ICI)NOMINAL CURRENT : 250A.	
Item (1): SOFT STARTER ATS48C25Q, ALTISTART 48, Qty (1)EA	

OR No. (25011143), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
MINIATURE CIRCUIT BREAKER DIN RAIL THREE POLE 380 VOLTS, 6KA R.C.	
Item (1): MINIATURE C.B.3 POLE 380V.RATING 63A Qty (15)EA	

OR No. (25011143), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
SPARES FOR FUEL OIL AND NAPHTHA ADDITIONAL STORAGE TANKS, 90 KW. LOCATION: TANK FARM.	
Item (2): AIR BREAKER CONTACTOR 220V(3TF5222-OAPO) Qty (1)EA	

OR No. (25011143), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
ELECTRICAL ACCESSORIES.	
Item (3): INSULATED PIN TERMINALS BLUE VINYL . DVP2-12 Qty (350)EA	

OR No. (25011143), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
MINIATURE CIRCUIT BREAKER DIN RAIL 230V, 50HZ. MINIATURE CIRCUIT BREAKER 230V,32A, DOUBLE(1P+N)BREAKING CAPACITY 4.5KA, DIN-RAIL TYPE	
Item (4): MINIATURE CIRCUIT BREAKER 230V 30A,DOUBLE(1P+N) Qty (30)EA	

OR No. (25011143), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
SPARES FOR REFINERY ELECTRICAL MOTOR CONTROL CENTER AND DISTRIBUTION PANELS MCC AND DB. LOCATION : 3RD. EXP. PROJECT . SINGLE POLE CIRCUIT BREAKER 230V,1A BREAKING CAPACITY 4.5KA,DIN RAIL TYPE.	
Item (5): SINGLE POLE CIRCUIT BREAKER 230V,1A Qty (10)EA	

OR No. (25011143), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
SPARES FOR REFINERY ELECTRICAL MOTOR CONTROL CENTER AND DISTRIBUTION PANELS MCC AND DB LOCATION : 3RD. EXP. PROJECT . CURRENT TRANSFORMERS :-	
Item.(6): CTS 600/5A, 10VA/0.5,TYPE ADF-2E(RING) Qty (3)EA	

OR No. (25011143), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
CURRENT TRANSFORMER-RING TYPE 100/1, 5VA/0.5 MAX.VOLTAGE 600 V , FREQ 50/HZ. ACCURACY CLASS 0.5, BASES FOR BACK PLATE . INTERNAL DIAMETER MAX 32 MM. OUTER DIAMETER MAX 70 MM THICKNESS 73 MM	
Item (7): CURRENT TRANSFORMER-RING TYPE 100/1,5VA/0.5 Qty (6)EA	

OR No. (25011143), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
DC Miniature Circuit Breaker Din Rail. Suitability for industrial isolation according to IEC/EN 60947-2 standard Combine short-circuit and overload currents protection Application: For use in DC distribution panels Rated operational voltage: 220 VDC Rated insulation voltage: 500 V DC rated impulse withstand voltage: 6 kV Rated breaking capacity: 20 kA Icu at 220 V DC. Tripping characteristic: Thermal-Magnetic, Curve C Number of poles: 2P Shall be provide the following: 1- Technical catalogues and datasheets. 2- Test certificates proving compliance with IEC standards.	
Item (8): DC Miniature Circuit Breaker, 1A Qty (100)EA	
Item (9): DC Miniature Circuit Breaker, 5A Qty (50)EA	
Item (10): DC Miniature Circuit Breaker, 10A Qty (10)EA	
Item (11): DC Miniature Circuit Breaker, 16A Qty (10)EA	
Item (12): DC Miniature Circuit Breaker, 20A Qty (10)EA	
Item (13): DC Miniature Circuit Breaker, 25A Qty (10)EA	
Item (14): DC Miniature Circuit Breaker, 2A Qty (50)EA	
Item (15): DC Miniature Circuit Breaker, 3A Qty (50)EA	

OR No. (25011143), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
MITSUBISHI NO FUSE AIR CIRCUIT BREAKER 380 VOLTS THREE POLES WITH THERMAL RELAY . SPECIFICATION - MITSUBISHI MOLDED CASE CIRCUIT BREAKER - TYPE NF 100-SP,T/A - RATING (100)AMP - THERMAL ADJUSTABLE RANG (80-100)AMP.	
Item (16): MITSUBISHI MOLDED CASE CIRCUIT BREAKER TYPE NF 100-SP T/A Qty (5)EA	

OR No. (25011147), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
Item (1)	
HIGH IMPACT PLASTIC CABLE TRUNK COMPLETE WITH COVER SUITABLE FOR ELECTRICAL INSTALLATIONS.	
DIM.25X16MM	
COVER IS TO BE CLIP-ON LID FOR SECURITY AND EASILY REMOVABLE WITH STANDARD DEPTH ACCORDING TO BS 4678 PART 4, STANDARD LENGTH 3 METERS .	
Qty (504)M	

OR No. (25011147), OQ No. () (Each point must be confirmed/commented upon and must be submitted with the offer)	
Technical Requirements	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
Item (2)	
PLASTIC CABLE TIES 20CM. LENGTH.	
Qty (1500) EA	

00 No. (25010581)

(Each point must be confirmed/ commented upon and must be submitted along with the offer)

SN	Requirement	Vendor's confirmation/ acceptance/ comments to be mentioned for each item
1	Manufacturer name	
2	Full address	
3	Supplier name	
4	Full address	
5	Offer no.	
6	Offer validity (at least 90 days from closing date)	
7	Indicate the quoted currency.	
8	Indicate Country of Origin of goods offered	
9	Accordance to Jordan prevailing law, you should pay 6 per thousand of the total order to cover the REVENUE STAMPS	
10	Promised delivery date shall be provided.	
11	Price Inclusive/Exclusive Sales Tax	
12	Local supplier registration in the National E-Invoicing System	

Order No. OR-(, OQ-(25010581)

(Each point must be confirmed/ commented upon and must be submitted along with the offer)

1	Manufacturer name	
2	Full address	
3	Supplier name	
4	Full address	
5	Offer no.	
6	Offer validity (at least 90 days from closing date)	
7	Indicate the quoted currency.	
8	Indicate Country of Origin of goods offered	
9	Indicate Country of Shipping of goods offered	
10	Details of Packing of goods offered.	
11	Accordance to Jordan prevailing law, you should pay 6 per thousand of the total order to cover the REVENUE STAMPS	
12	Payment terms: (CAD, NET 30 days)	
13	Any extra optional and/or additional services should be clearly detailed and priced.	
14	Confirmation that the quoted prices are valid for acceptance up to 90 days from the due date / extended due date of requisition.	
15	Promised delivery date shall be provided.	
16	For Local Suppliers: • The offered prices shall be inclusive of all taxes, duties, and other applicable charges. • Breakdown of taxes and charges shall be provided with commercial offer	
17	For Foreign Suppliers: Confirm that all taxes, duties & levies of any kind up to port of shipment shall be borne by supplier.	